



Water Chemical Analysis

174 05442

Client: King Water Company
PO Box 2243
Oak Harbor, WA 98277

Invoice Number: 21-01353
PO Number:
Project Name: PFOA/PFOS

Approved By:

PWS Information

Date Collected: 1/25/2021
System Number: 18305
Lab Sample Number: 174 05442
Sample Location: Sample: SO2 - Well 2
Sample Purpose: Investigative
Sample Composition: Samples from a single source

System Group Type:
System Name: DECEPTION PARK VIEW
County: ISLAND
Source Number: 02
Date Received: 1/26/2021
Date Analyzed: 2/4/2021
Date Reported: 2/19/2021
Sample Type: Post Treatment/Finished Water Sample

Sample Collected by:

DOH #	Analyte	Results	Units	SRL	Trigger	MCL	Method	Analyst
General Chemistry								
0	Perfluorohexanesulfonic acid - PFH*	ND	ug/L	0.0020			EPA 537	OS
0	Perfluorooctanesulfonic acid - PFOS*	ND	ug/L	0.0020			EPA 537	OS
0	Perfluorooctanoic acid - PFOA*	ND	ug/L	0.0020			EPA 537	OS
0	Perfluorobutanesulfonic acid - PFBS*	ND	ug/L	0.0020			EPA 537	OS
0	Perfluoroheptanoic acid - PFHpA*	ND	ug/L	0.0020			EPA 537	OS
0	Perfluorononanoic acid - PFNA*	ND	ug/L	0.0020			EPA 537	OS

MCL = (Maximum Contaminant Level) allowed by the State of Washington.

ND = (Not Detected) Compound was analyzed and not detected at a level greater than or equal to the SRL.

SRL = (State Reporting Level) The minimum reporting level required by Washington State Department of Health (DOH).

Trigger Level = DOH drinking water response level. System with compounds detected at concentrations in excess of this level are required to take additional samples.

< = (less than) indicates the analyte was below the detection limit.

*Analysis performed by BSK Associates